

Complete Fixture consists of Frame-In Kit and Reflector Trim. Select each separately.

Uniframe™ Compact Fluorescent Performance Series Reflector Trims		Compatible Frame-In Kits (See Individual Frame-In Kit Specification Sheets)		
Catalog No.	Description	Catalog No.	Installation Type	Lamping
1001HACB 1001HWHCB	5" Horizontal Shielded Cross Blade – Aluminum 5" Horizontal Shielded Cross Blade – Matte White	1001F13U	Uniframe™ Non-IC 120/277v	13w Quad/Triple
		1001F18U 1001FR18U 1001F18UEM	Uniframe™ Non-IC 120/277v Uniframe™ Non-IC Remodeler 120/277v Uniframe™ Non-IC Emergency 120/277v	18w Triple
		1001F26U 1001FR26U 1001F26UEM	Uniframe™ Non-IC 120/277v Uniframe™ Non-IC Remodeler 120/277v Uniframe™ Non-IC Emergency 120/277v	26w Triple
		1001FD26L1 1001FD26L2	Uniframe™ Non-IC Lutron Dimming 120v Uniframe™ Non-IC Lutron Dimming 277v	26w Triple
		1001FD26MX1 1001FD26MX2	Uniframe™ Non-IC Advance Mark10 Dimming 120v Uniframe™ Non-IC Advance Mark10 Dimming 277v	26w Triple
		1001FD13M7U	Uniframe™ Non-IC Advance Mark7 Dimming 120/277v	13w Triple
		1001FD18M7U	Uniframe™ Non-IC Advance Mark7 Dimming 120/277v	18w Triple
		1001FD26M7U	Uniframe™ Non-IC Advance Mark7 Dimming 120/277v	26w Triple
		1001FRD26MX1 1001FRD26MX2	Uniframe™ Non-IC Advance Mark10 Dimming 120v Rem. Uniframe™ Non-IC Advance Mark10 Dimming 277v Rem.	26w Triple
		1001F13ICU/N	Performance IC 120/277v	13w Quad/Triple
		1001F18ICU/N	Performance IC 120/277v	18w Triple
		1001F26ICU/N	Performance IC 120/277v	26w Triple
		1001FDICMX1/N 1001FDICMX2/N	Performance IC Advance Mark10 Dimming 120v Performance IC Advance Mark10 Dimming 277v	26w Triple

Features

- Reflector:** Formed aluminum. Matte White flange.
- Finishes:** WH = Matte White Paint
A = Aluminum Paint
- Cross Blade:** .50" thick aluminum "floating" cross blade painted white or aluminum.
- Performance Data:** 60° Cutoff angle.
See attached photometric reports for distribution and efficiency data.
Go to www.lightolier.com for .IES files.

Labels

cULus Listed. Suitable for Damp Locations. I.B.E.W.

Job Information

Type:

Job Name:


Cat. No.:

Lamp(s):

Notes:



26W TRIPLE TUBE LAMP, LUMEN RATING = 1710 LMS, ELECTRONIC BALLAST, WHITE CROSS BLADE



SC = 0.88 x 1.02

1 - 0°

2 - 90°

CERTIFIED TEST REPORT NO. 3347FR

COMPUTED BY LSI PROGRAM

**TEST-LITE*

Angle	CANDLEPOWER SUMMARY		ZONAL LUMEN SUMMARY		ZONAL LUMENS AND PERCENTAGES			
	0° CP	90° CP	Zone	Lumens	Zone	Lumens	%Lamp	%Fixt
0	410	410	0-10	38.54	0-30	259.77	15.2	49
5	399	416	10-20	99.44	0-40	361.86	21.2	68.3
10	371	412	20-30	121.79	0-60	475.74	27.8	89.8
15	332	379	30-40	102.09	0-90	529.86	31	100
20	291	352	40-50	67.1	90-120	0	0	0
25	254	310	50-60	46.79	90-150	0	0	0
30	214	247	60-70	31.49	90-180	0	0	0
35	170	178	70-80	17.63	0-180	529.86	31	100
40	124	114	80-90	5				
45	90	75	90-100	0				
50	69	62	100-110	0				
55	51	51	110-120	0				
60	41	40	120-130	0				
65	32	32	130-140	0				
70	24	24	140-150	0				
75	17	17	150-160	0				
80	10	10	160-170	0				
85	4	5	170-180	0				
90	0	0						

** Efficiency = 30% **

Ceiling	COEFFICIENTS OF UTILIZATION															
	80%				70%				50%				30%			
Wall	70	50	30	10	50	10	50	10	50	10	50	10	50	10	50	10
RCR	Zonal Cavity Method - Effective Floor Reflectance = 20%															
0	37	37	37	37	36	36	33	33	32	32	32	32	31	31	31	31
1	34	33	32	31	33	31	31	30	30	29	29	27	27	27	27	27
2	32	30	28	27	29	27	28	26	27	25	24	24	24	23	23	23
3	30	27	25	24	27	23	26	23	25	23	22	22	22	21	21	21
4	28	25	23	21	24	21	24	21	23	20	19	19	19	18	18	18
5	26	23	21	19	16	19	22	19	21	18	18	18	18	17	17	17
6	24	21	19	17	21	17	20	17	20	17	16	16	16	15	15	15
7	23	19	17	16	19	16	19	15	18	15	15	15	15	14	14	14
8	22	18	16	14	18	14	18	14	17	14	14	14	14	13	13	13
9	20	17	15	13	17	13	16	13	16	13	13	13	13	12	12	12
10	19	16	14	12	16	12	15	12	15	12	12	12	12	11	11	11

Determined In Accordance With Current IES Published Procedures
Luminaire Input Watts = 33.0

Job Information	Type:
------------------------	--------------